



Resource & Environmental Consultants (Asbestos) Ltd



2520



CONTRACTORS HEALTH & SAFETY ASSESSMENT SCHEME

Background / Reassurance Air Monitoring		12-MOY-A-1714	
Procedure: documented in house procedure REC ASB 02		Customer Order	0
		Issue Date	08/06/2012
Site Location	Bloomfield Collegiate School, Astoria Gardens, Belfast, BT5 6HW		
Areas and Description of Work	Reassurance air tests in classroom 34 following storage of items removed from an area with asbestos containing products identified		
Date sampled	08/06/2012	Date counted	08/06/2012
Sampled by	Maurice Gillanders	Slides Counted by	Maurice Gillanders
Sign		Sign	
Client	Bloomfield Collegiate School, Astoria Gardens, Belfast, BT5 6HW		
Asbestos Removal contractor	NA		
Report Generated From	Moy		
Location Slides Counted	Moy Lab		

Dust Disturbance & Environmental Conditions

Method used	Total Time		Temp °C	Press mb
Brush	0.00	Mins	On site	19
				989

Fibre Count Details

Sample No.	Location/Name/Activity	Sample Type	Time		Volume Sampled (l)
			Start	Finish	
1	Room 34 - Centre LHS	Background	11:30	12:08	608.0
2	Room 34 - Centre RHS	Background	11:31	12:08	592.0
3	Room 34 - Centre LHS	Reassurance	12:14	12:59	720.0
4	Room 34 - Centre RHS	Reassurance	12:15	12:59	704.0

Sample No.	Flow Rate (l/min)			Graticule Areas Examined	No. Of Fibres Counted	Reported Fibre Conc (fibres / cm3)	Limit Of Quantification (fibres / cm3)
	Start	Intermediate	Finish				
1	16.0	---	16.0	200	6.5	<0.01	0.01
2	16.0	---	16.0	200	4.5	<0.01	0.01
3	16.0	---	16.0	200	10.5	<0.01	0.01
4	16.0	---	16.0	200	9.5	<0.01	0.01


Graticule Diam. (µm) : 100 Exposed Filter Diam. (mm) : 22.25 No. of NPL Blocks Observed : 5/6
The fibrecounts obtained were below the Health and Safety Clearance indicator of 0.01 f/cm3

Comments: Air tests 1 and 2 taken without disturbance in the room, tests 3 and 4 taken after disturbance of hard surfaces and materials. Air tests results were below the H&S clearance indicator of 0.01f/cm3

Disclaimer: Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.



Sketch



[

REC Braintree	Environment House, Bullocks Lane, Takeley, Bishop's Stortford Herts, CM22 6TA T. 01279 879 416 F. 01279 879 414
REC East Kilbride	16 Langlands Place, Kelvin South Business Park, East Kilbride, Glasgow, G75 0YF T. 01355 573360 F. 01355 573351
REC Manchester	Osprey House, Pacific Quay, Broadway, Manchester, M50 2UE T. 0161 868 1300 F. 0161 868 1301
REC Port Talbot	Unit 19, Kenfig Industrial Estate, Margam, Port Talbot, SA13 2PE T. 01656 749823 F. 01656 740824
REC Moy	69A Killyman Street, Moy, Co. Tyrone, BT71 7EA T. 028 8778 9180 F. 028 8778 9171